





## CERTIFICATE

No. Z2 072701 0005 Rev. 00

**Holder of Certificate:** HIMIN CLEAN ENERGY HOLDINGS CO.,

LTD.

Sun-moon Mansion, Solar Valley Road 253090 Dezhou City, Shandong Province PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:** 



**Product: Crystalline Silicon Terrestrial Photovoltaic** 

(PV) Modules

Mono-Crystalline Silicon Photovoltaic

Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 882162006601

Valid until: 2025-11-12

Date, 2020-12-02

(Xinlian LUO)



## CERTIFICATE

No. Z2 072701 0005 Rev. 00

Model(s): 158.75mmx158.75mm cells module types:

HG-xxxS/Ec (xxx=340-390, in step of 5W)
HG-xxxS/Dc (xxx=285-330, in step of 5W)
HG-xxxS/Cc (xxx=255-290, in step of 5W)
HG-xxxS/Bc (xxx=230-260, in step of 5W)
HG-xxxS/Ac (xxx=170-195, in step of 5W)
156.75mmx156.75mm cells module types:
HG-xxxS/Ea (xxx=340-390, in step of 5W)
HG-xxxS/Da (xxx=285-330, in step of 5W)
HG-xxxS/Ca (xxx=255-290, in step of 5W)
HG-xxxS/Ba (xxx=230-260, in step of 5W)
HG-xxxS/Aa (xxx=170-195, in step of 5W)

xxx is standing for rated output power at STC

## **Parameters:**

Construction: Framed, with Junction box, Cable and Connectors Test Laboratory: Yangzhou Opto-electrical product testing institute (10 Kaifa West Rd., Yangzhou, Jiangsu, P. R. China 225009)

Safety Class: Class II

Maximum System Voltage: 1000V DC

Fire Safety Class: Class C according to UL790

**Tested according to:**IEC 61215-1:2016

IEC 61215-1-1:2016

IEC 61215-2:2016

IEC 61730-1:2016 IEC 61730-2:2016 EN 61215-1:2016 EN 61215-1-1:2016 EN 61215-2:2017 EN IEC 61730-1:2018

EN IEC 61730-1:2018/AC:2018-06

EN IEC 61730-2:2018

EN IEC 61730-2:2018/AC:2018-06

Production 072701

Facility(ies):

TÜV®